



Application Information

Fixed Control Multipump System

Equipment: CFW-11

Firmware Version: V1.30 or higher

WLP Software Version: V7.23 or higher

New Application Version: MPFIC-1_04.apl

Old Application Version: MPFIC-1_03.apl

Document: 10000123067 / 00

Functional deviations in the old application version

1) The alarms A770, A772, A774 and A776 were generated when the multipump system was in local mode.

Changes in the new application version

1) -

Notes!

1) Appendix 1 shows how to import Fixed Control Multipump System application to WLP.

Appendix 1 – How to Import Application to WLP

- 1) In the WLP Ladder Programmer, in "Tools" menu, select the "Import Application to WLP" option;
- 2) Search "MPFIC-1_04.apl" archive and press "OK";
- 3) The Fixed Control Multipump System will be imported to WLP;
- 4) To select the application, in "Tools" menu, "Application" option, "CFW11", "Create", "Multipump", select "Fixed Control" option.