


Electronic Board CC900

CTW900

Configuration Guide Guía de Configuración Guia de Configuração

English / Español / Português

Document: 10002895190 / 01



English

After the installation of the new board on CTW900, you must set the parameter P0295 with the rated current of the converter.

To do this, follow the procedure below:

- set P0000 = 1734;
- change the value of P0295 according to rated current of CTW900, printed on the identification label of the product;
- set P0000 = 0.

Español

Después de instalar la nueva tarjeta en CTW900, debe configurar el parámetro P0295 con la corriente nominal.

Para ello, siga el procedimiento siguiente:

- programa P0000 = 1734;
- cambiar el valor de P0295 de acuerdo con la corriente nominal de CTW900, impreso en la etiqueta de identificación del producto;
- programa P0000 = 0.

Português

Após instalar o novo cartão no CTW900, deve-se programar o parâmetro P0295 com a corrente nominal do conversor.

Para isso, siga o procedimento abaixo:

- programe P0000 = 1734;
- altere o valor de P0295 de acordo com a corrente nominal do CTW900, impressa na etiqueta de identificação do produto;
- programe P0000 = 0.