



## Application Information

Floating Control Multipump System

Equipment: CFW-11

Firmware Version: V1.30 or higher

WLP Software Version: V7.23 or higher

New Application Version: MPFLC-1\_03.apl

Old Application Version: MPFLC-1\_02.apl

Document: 10000123460 / 00

### Functional deviations in the old application version

1) The multipump system enabled the sleep mode so wrong and only the CFW11 pump was disabled.

### Changes in the new application version

1)

### Notes!

1) Appendix 1 shows how to import Floating Control Multipump System application to WLP.

## Appendix 1 – How to Import Application to WLP

- 1) In the WLP Ladder Programmer, in “Tools” menu, select the “Import Application to WLP” option;
- 2) Search ‘MPFLC-1\_03.apl” archive and press “OK”;
- 3) The Floating Control Multipump System will be imported to WLP;
- 4) To select the application, in “Tools” menu, “Application” option, “CFW11”, “Create”, “Multipump”, select “Floating Control” option.