



## Application Information

Floating Control Multipump System

Equipment: CFW-11

Firmware Version: V1.30 or higher

WLP Software Version: V7.23 or higher

New Application Version: MPFLC-1\_04.apl

Old Application Version: MPFLC-1\_03.apl

Document: 10000123460 / 00

### Functional deviations in the old application version

- 1) The alarms A770, A772, A774 and A776 were generated when the multipump system was in local mode.
- 2) When the wake up mode activation time (P1033) was lower than 0.50s and the F763 fault occurred, in the reset command, all pumps in the multipump system were started at the same time.

### Changes in the new application version

- 1)

### Notes!

- 1) Appendix 1 shows how to import Floating Control Multipump System application to WLP.

## Appendix 1 – How to Import Application to WLP

- 1) In the WLP Ladder Programmer, in "Tools" menu, select the "Import Application to WLP" option;
- 2) Search 'MPFLC-1\_04.apl" archive and press "OK";
- 3) The Floating Control Multipump System will be imported to WLP;
- 4) To select the application, in "Tools" menu, "Application" option, "CFW11", "Create", "Multipump", select "Floating Control" option.